


## ASSEMBLY INSTRUCTIONS

### READ CAREFULLY



Model No.	Inside Dimensions	Outside Dimensions	Recommended Concrete Pad Dimensions
800S-Series	38"W x 144"L x 56"H	41 3/4"W x 147 1/8"L x 59 1/4"H	52"W x 158"L x 6" Thick
800TS-Series	38"W x 144"L x 80"H	41 3/4"W x 147 1/8"L x 83 1/4"H	52"W x 158"L x 6" Thick

1. Center a 6" thick concrete base around installed BFP.
  - A. Place expansion material around riser pipe and place conduit for electrical power before placing concrete. **CONCRETE SHOULD BE FINISHED ABSOLUTELY LEVEL, FLAT AND SMOOTH.** Allow concrete to cure.
  - B. Mark concrete with outside dimensions of enclosure. Center enclosure around BFP.
2. Using four (4) hexhead screws for each section assemble each "A-B" (end and side) sections thru holes provided. Set on marked concrete base (FIG 2).
3. Set "D1" (roof) panel on "A-B" sections. Using two (2) hexhead screws fasten thru holes provided (Fig 1).
  - A. **"Temporarily"** place "F" (center) post in position.
4. Position "D2" (roof) panel over edge of "D1" (roof) panel and set on other "A-B" section. Using two (2) hexhead screws fasten thru holes provided (Fig 1).
5. On top inside of roof, using ten (10) hexhead screws attach **Inner Roof Connection Bracket (Fig 1E)** to "D1" (roof), "D2" (roof) and both "F" (side) posts. (This will cover the wood members in the center of the top and secure the top to the "F" post.)




FIG 2

6. A. Using one (1) hexhead screw attach **Outside Corner Anchoring Brackets** to "A-B" sections. Fasten bracket to concrete using one anchor for each bracket (FIG 1A).
- B. Square the "A-B" corners. Align the "B" panels so that they form a straight line. Using one (1) hexhead screw and one (1) hit pin for each bracket attach **Inside Anchoring Brackets** to "B" panels and concrete (FIG 1B).
- C. Insert **Inside Roof Clips** in "D" (roof) panel. Using one (1) hexhead screw in each clip attach clip to "B" (side) panel (FIG 1C).

7. A. Align "F" (center) post in the center of the opening.  
B. Install **Inside Anchoring Brackets** (Fig 1B) at bottom of the "F" posts.
8. On outside at "D1-D2" (roof) seam, install **Roof Cover Plates** (Fig 1D) on each side of enclosure. (Fig 1D).
9. Set "C" panels and lock in place. (Solid "C" panel to be the **ACCESS DOOR PANEL**).
10. Provide ground-fault interrupter device in electrical circuit according to applicable codes. Install heater as per manufacturer's instructions and governing local and national codes.
11. For maximum protection it is suggested that the area between the bottom of the enclosure and the concrete base be caulked with the exception of the "C" panels. **DO NOT CAULK THE BOTTOM OF THE "C" DOOR PANELS.**

**REMOVE MASKING FILM IMMEDIATELY  
AFTER INSTALLATION.**

*If these panels get wet when the film is still on, water will irreversibly stain the panels. Summertime heat will bake the film on the panels.*

## **CONTENTS**

**Model No. 800S-Series  
Model No. 800TS-Series**

- 2- "A" (end) Panels**
- 4- "B" (side) Panels**
- 1- "C" (drain door) Panel**
- 3- "C" (solid access) Panels**
- 2- "D" (roof ) Panels**
- 2- "F" Panels**
- 1- Inner Roof Connection Bracket (With tabs for "F" posts)**
- 2- Roof Cover Plates**
- 4- Outside Corner SS Anchoring Brackets (2½" x 2 ½")**
- 6- Inside Aluminum Anchoring Brackets (3" x 3")**
- 4- Inside Roof Clips**
- 10- Wedge Anchors**
- 42- Screws**
- 1- Masonry Bit**
- 1- Magnetic Chuck**

## **TOOLS NEEDED**

**Hammer**

**Drill**

**7/16" Wrench**