ENCLOSURE MODEL: 800T-AL JOB: by HydroCowl Tennessee Drawn By: PP Scale: None Date: 06/26/13 615-259-4481 FAX 615-259-4495 800-245-6333 **ELEVATION VIEW** 12" AMES O&Y REMOVABLE ACCESS 9 1/2" PANEL: 38 1/4" x 80" 12-2000SS-OSY Sheet 1 of 58 1/2" 80" 12" HCH2000-120 SLAB MOUNT HEATER MODEL 800T-AL ENCLOSURE. BFP - 12" AMES 2000SS OS&Y 9 11/16"-**⊁21 1/2**" ·21 1/2" 9 13/16" ·57 1/2" Concrete pad is 52"W x 134"L Enclosure inside dimensions: SLAB HEATER IS WET/DAMP CERTIFIED PER ASSE 1060 CLASS I **PLAN VIEW** ထံ တံ Wall and insulation thickness is 1-1/2" BFP dimensions furnished by AMES Roof and insulation thickness is 3", 9 1/2" All dimensions are in inches. 19" 38" 52" 1. Drawing NOT TO SCALE. 9 1/2" HINGED DRAIN OPENING 4.

CONFIDENTIAL: This drawing is intended for use only by those authorized to receive it.

Dissemination, distribution or copy of this information is strictly prohibited. US PATENT 5,609,784