

ENCLOSURE MODEL: 300T-AL

JOB:

Drawn By: PP Scale: NONE Date: 7-10-13


**SAFE-T-COVER**

BY: HYDROCOWL


2710 LANDERS AVENUE, NASHVILLE, TN 37211  
615-259-4495, 800-245-6333, 615-259-4481 FAX

ELEVATION VIEW

SLAB HEATER IS  
WET/DAMP CERTIFIED  
PER ASSE 1060  
CLASS I



PLAN VIEW



4AM5000SS-OSY12

Sheet 1 of 1

6. HYDROCOWL MODEL 300T-AL ENCLOSURE.

7. Enclosure inside dimensions:  
22"W x 72"L x 50"H

8. Concrete pad is 36"W x 85"L

9. BFP - 4" AMES 5000SS OS&Y

1. Drawing NOT TO SCALE.

2. BFP dimensions furnished by AMES

3. All dimensions are in inches.

4. Wall and insulation thickness is 1-1/2".

5. Roof and insulation thickness is 3".

CONFIDENTIAL: This drawing is intended for use only by those authorized to receive it. Dissemination, distribution or copy of this information is strictly prohibited.