ENCLOSURE MODEL: 600T-AL JOB: by HydroCowl Tennessee Drawn By: PP Scale: None Date: JUNE 2013 615-259-4481 FAX 615-259-4495 800-245-6333 **ELEVATION VIEW** 8" C300 AMES SLAB HEATER IS WET/DAMP CERTIFIED PER ASSE 1060 CLASS I OS&Y 8AMC300-OSY-12 Removable Access Panel One Each Side: 38 1/4 x 64 Sheet 1 of 64 3/4 ဖ AMES C300 DCDA -OSY **HCH SLAB MOUNT HEATER** 1 ٠ ۵ MODEL 600T-AL ENCLOSURE. Concrete pad is 50"W x 114"L Enclosure inside dimensions: 50" ^{_}9 1/4" (TYP) 36"w x 100"L x 64"H **PLAN VIEW** - 114 100 ထဲ Hinged Drain Opening 22 15/16" Wall and insulation thickness is 1-1/2" BFP dimensions furnished by AMES. Roof and insulation thickness is 3". 50 36 △ All dimensions are in inches. Drawing NOT TO SCALE. HCH2000-120 SLAB MOUNT HEATER 4 Δ ٠. Removable Access Panel Openings Two Openings: 38 1/4 x 64 **←** α α 4.

CONFIDENTIAL: This drawing is intended for use only by those authorized to receive it.

Dissemination, distribution or copy of this information is strictly prohibited. US PATENT 5,609,784